Secrt. II-27—45,004—14-11-29.

Law (Genl) (1930) Department.

Ms. SERIES.

G.O. No. 2259

DATED 28-5-1930

[Despatch Abstract.]

Petroleum

Special Licence - storage - Kerbside pump - Burma Shell Oil Storage and Distributing Company of India, Limited - Codialbail - Mangalore - Granted.

C.F. 30.

Law (General) **DEPARTMENT.**

Received 19 . *Registered* Q 3932C 19 J. 3.

Subject.

Petroleum - dangerous - Kerbside pump -special license - grant to the Burmah Shell Oil Storage and Distributing Co., of India,Ltd.- recommended.

ENCLOSURES.
No.
Spare copies

Ref.Cl- ~~No.~~ 3518-30.

Station Mangalore, , *Dated the* 15th May 1930.

From (Name) G. W. Wells, Esquire, M.A., I.C.S.,
(Designation) Dt. Magistrate of South Kanara.

To The Secretary to the Government of Madras,
Law (General) Department.
Madras.

Sir,

M 4-13 cl

I enclose the application of Messrs. Burmah Shell Oil Storage and Distributing Company of India,Limited,Madras for the grant of a special license to store 500 gallons of dangerous petroleum in their underground tank, situated on private land belonging to the Canara Public Conveyance Company, Limited, Mangalore at Codialbail, Mangalore.

M 13 cl

2. The site was inspected on 20-10-29 by the District Superintendent of Police, South Kanara, and found to be unobjectionable. The Company then proceeded with my ----- permission to construct the tank and erect the pump on the site selected. On receipt of intimation from them that the

construction was complete, the Sub-divisional Magistrate, Mangalore Division, at my request, inspected it and found that it satisfied all the conditions of the special license.

3. I enclose a copy of the letter dated 23-9-1929 of the Chief Inspector of Explosives, the Treasury Chalan receipt No.142/54 dated 4-4-30 of the Imperial Bank for the fees of rupees eight paid for the issue of the license, the certificate dated 11-4-30 of the Works Manager of the C.P.C.Company, and the report dated 5-5-30 of the Sub-divisional Magistrate, Mangalore Division. A copy of the form of special license sent by the Chief Inspector and a copy of the plan of the site approved by him are also enclosed.

4. The license may be granted.

Your obedient servant,

For Dt.Magistrate.

16.5.30

3

Enclosure to the letter Ref C-2518-20

dated 15.5.20 of the District Magistrate

of South Kanara.

ALL COMMUNICATIONS TO BE ADDRESSED TO THE COMPANY

BURMAH-SHELL

OIL STORAGE & DISTRIBUTING CO. OF INDIA LTD.

(INCORPORATED IN ENGLAND)

POST BOX No. 157.

TELEGRAMS:-"BURMAHSHEL"
TELEPHONE No. 3964 (4 LINES)

DEPT. PETROL.

FIRST LINE BEACH,

4

IN REPLY, PLEASE REFER TO NO. KP/323/E - C/4/13.

MADRAS, 25th March 19 30.

26

The District Magistrate,

South Canara District,

MANGALORE.

COLLECTOR'S OFFICE
2[illegible]30

Sir,

KERBSIDE PUMP: MANGALORE
Issue of Special License

Reverting to your letter No.C.1/8995/29 dated the 26th October, we have the honour to inform you that we have now completed the erection of the above pump and shall be much obliged if you will kindly grant us a special license to store 500 gallons of dangerous petroleum in the under tank.

We are this day asking the Canara Public Conveyance Co. Ld., Mangalore to pay into your office the requisite license fee together with any stamp fees that may be required. As we would like to bring this pump into commission at the earliest opportunity, we shall be extremely obliged if you will be so good as kindly to give this matter your early attention.

We have the honour to be,
Sir,
Your obedient servants,
For BURMAH-SHELL
OIL STORAGE & DISTRIBUTING CO.OF INDIA LD.

Encl: Nil.

EJS/NR.

The Canara Public Conveyance Co., Ltd.

PORT AND RAILWAY STATION } MANGALORE.

No. 69.

(Post) Codialbail 12th. Apr. 1930.

(SOUTH INDIA.)

TELEGRAMS:-"ENTERPRISE"

BANKERS:
Messrs. The Canara Banking Corporation, Udipi, Ltd., Mangalore.

To

The District Magistrate,
South Kanara, Mangalore.

Sir,

As required by your order Ref.Cl-3518-30 of 3rd.inst, we enclose a certificate of erection of the Tank herein.

The site belongs to us i.e. The Canara Public Conveyance Co.Ltd, Mangalore. The two sheds have been cleared of scrap iron and rubbish.

A court fee label of twelve annas and a treasury chalan receipt of Rs.8/- for license fees have also been enclosed.

I beg to remain,
Sir,
Your most obedient servant.

Secretary.

/NKN
Encls: Court fee label--1, chalan receipt--1 & a certificate.....

V. S. Kudva.

6

Camp

Codialbail, 11th.April 1930.



C E R T I F I C A T E.

This is to certify that the foundations of the Kerbside pump and tank in the grounds of Messrs. Canara Public Conveyance Co.Ltd, at Kodialbail were constructed before me and that the construction has been done according to the best practice and to the requirements of public safety.

Works Manager,
C.P.C.Co.Ltd, Mangalore.
&
Part time Assistant Lecturer
in Mechanical Engineering in
The Government Trades School,
Mangalore.

1765-30

Submitted for orders:-
It is may
in order to
Very Urgent
Ref G- 3518-30
29/4/30

I shall do it on the 3rd
29.4.30
If there is no salt case I shall do it on the 5th
4.5.30

Forwarded with the report dated 20.10.1929 of the District Superintendent of Police, South Kanara, (ii) the plan of the locality and (iii) a copy of the form of Special licence to be issued in this case - to the Sub Divisional

8 7

Magistrate, Mangalore Division for

inspection and report whether the construction is

complete, and whether it satisfies the conditions of

the license.



23·4·1930 } for District Magistrate

Misst. - Forwarded to the Sub Divisional Magistrate Mangalore as this is intended for him

Mangalore 24/4/30

Dr. Dis 1765-30-C.

for Dt. Supdt. of Police
South Kanara

Submitted to the Dt Magistrate. Inspected the construction and find that it is complete & that it satisfies the conditions in the license.

T. & A. 218—118 Bks.—15-8-29.

T. & A. 218.

No. 54

DUPLICATE.

Chalan for payment of money into the Imperial Bank of Madras at Mangalore.

By whom paid.	On what account.	Amount. RS.	A.	P.	Reference to Revenue Register.
The Burma Shell Oil Storage & Distributing Co. of India Limited Madras.	Licence fee of new Kerosene & Petrol Pumps at Kodialbail & Mangalore.	8	0	0	XVII - admissible of 9 Licence fees & fees for Petroleum Licence.
	Total (in words and figures) Rupees Eight only				

Imperial Bank of Madras at Mangalore

The 4-4-1930. Entered—Correct.

H. Krishna Rao
Signature of Remitter.

Initials of Treasury Accountant.

RECEIVED RUPEES.

Dated 19

Signature of Cashier.

Received Payment
APR 4 1930
THE IMPERIAL BANK OF INDIA
Bank Accountant.

Signature of Agent.

C No 1532
Pm 29

Form P. 14.

ALL COMMUNICATIONS TO BE ADDRESSED TO THE COMPANY

BURMAH-SHELL

OIL STORAGE & DISTRIBUTING CO. OF INDIA LTD.

(INCORPORATED IN ENGLAND)

TELEGRAMS:- "BURMAHSHEL"
TELEPHONE No. 3964 (4 LINES)

POST BOX
MADRA

IN REPLY PLEASE REFER TO No. P/140/E

24th September 1.

The District Magistrate,
South Canara,
MANGALORE.



Sir,

Proposed Kerbside Pump.

Canara Public Conveyance Co., Mangalore.

We have the honour to enclose a blue print of a site we have selected in Mangalore where we propose erecting a Petrol Kerbside Pump outfit and request you to be good enough to inspect the site and permit us to proceed with the erection of the pump.

The land is privately owned and the owner has agreed to lease it to us on a rental agreement.

The plant consists of a Pump of the latest pattern connected by underground pipes to a gas tight metal tank of 500 gallons capacity to be sunk completely below the ground level and placed in a pit lined with concrete or brick in cement, the tank being packed round with sand, earth or clay so that no air space is left below the ground level.

We have also applied to the Chief Inspector of

Form P. 11.*

- 2 -

BURMAH-SHELL
OIL STORAGE & DISTRIBUTING CO. OF INDIA LTD.
(INCORPORATED IN ENGLAND)
MADRAS.

Explosives in India, Calcutta for approval of our plan with a request to address you for the issue of a special license under Rule 6, Chapter IV, Part II of the Petroleum Act. Meanwhile, we shall be much obliged to receive your permission to enable us to proceed with the erection.

We have the honour to be,
Sir,
Your obedient servants,
For BURMAH-SHELL
Oil Storage & Distributing Co. of India Ltd.
E J Skipper

Encl; 1 blue print.

EJS/PRR

7 OCT 1929

NR. 4-8992-27

Forwarded to the District Superintendent of Police South Kanara for remarks please, whether the site is objectionable from the point of view of volume of public traffic at the place or of danger to public.

The plan is enclosed

5.10.29 District Magistrate

14 13

Re transmitted to the District Magistrate, Santhal Parganas.

2. There is no objection to the erection of a kerbside pump in the place proposed.

3. I would however suggest that the scraping shed close by & the rubbish shed, may not be utilised for the storage of scrapings & rubbish, as in case of an explosion, the reverberation may cause danger to the public.

[illegible]

20.10.29

Draft reply to the Company — for us.

[illegible]

16

Copy of letter No. P.L.XI-51(6), dated 23rd September 1929, from the Officiating Chief Inspector of Explosives in India, Calcutta, to the District Magistrate of Malabar, Calicut.

I have the honour to forward herewith a copy of a letter No.P/110/E, dated the 17th/18th September 1929 from the Burma Shell Oil Storage and Distributing Co. of India, Ltd., Madras, and a copy of a plan showing the site proposed for the installation of an underground petrol tank of 500 gallons capacity fitted with a kerbside pump at Mangalore and to state that the plan meets with my approval and I see no objection to the grant of a special licence under Rule 6, Chapter IV, Part II of the Petroleum Rules.

2. Two copies of the special licence form with conditions to be observed are enclosed.

3. If the special licence is granted, the necessary -- particulars may be given in the next half yearly return of -- petroleum licences to be submitted to this office.

True Copy.

for Dt.Magistrate.

16.5.30

Sectt. H-5 (a)—50,006—5-11-29.

Law (General) DEPARTMENT.

	Date.	Initials.
When received for Fair-copying.		
When copied ..	25/5	
When examined ..		
When signed ..	26/5/30	
When despatched ..		

Petroleum

Special licence – Storage – Hand-side pump – Burma Shell Oil Storage and Distributing Co. of India, Ltd – Cotiabail – Mangalore – granted

READ AGAIN G.O. No. ....., dated 19

" " " " " 19

READ ALSO :—

C. No. 3782C From the Dn., South Kanara, No. Ref C-3028-30, dated 15.5.1930

" " " " " 19

" " " " " 19

ASSISTANT SECRETARY TO GOVT. 24 MAY 1930 LAW DEPT.

ORDER. No. 2259, dated 26.5.30 19

Mcs.

A special licence under rule 6, chap IV Part II of the Petroleum Rules is granted to the Burma-Shell Oil Storage and Distributing Company of India, Limited for the storage of 500 (five hundred) gallons of dangerous petroleum in their underground tank at Cotiabail, Mangalore.

2. The licences will be forwarded to the Dy. Comr. South Kanara for delivery to the firm.

To the Dy. Comr., South Kanara with licence

The Chief Inspector of Explosives in India with Copy of licence

Copy to the Burmah Shell Oil St. Dd. Co. of India (Confidential)

Dy. Secy 24/5/30 SR 4530

Rule 1, Chap IV, Part II

"Save as provided in Rules 9(1), 13 & 14 of this

S. (Agency) 72. "Chapter every license for the possession of

"petroleum shall remain in force

"until the 31st December next following

"the date of issue of the licence"

Special License to possess dangerous petroleum, ~~acetone, wood naptha and methyl alcohol~~ in one receptacle or more than one receptacle forming one unit and containing more than sixty-five gallons.

(Rule 6, Chapter IV of Part II.)

No.

Fee Rs. 8/-
(Eight only)

License is hereby granted to the Burma Shell Oil Storage and Distributing Company of India, Limited for the storage in the licensed premises described below of 500 gallons of dangerous petroleum, ~~acetone, wood naptha and methyl alcohol~~ in one tank subject to the rules for the storage of petroleum, ~~acetone, wood naptha and methyl alcohol~~ published in notification No. 441, dated the 24th July 1908 and to the further conditions attached hereto.

O/C

The May 1930 Secretary to the Government of Madras
Law Department

[Description of the licensed premises above referred to.]

The licensed premises are situated in the private land belonging to the Canara Public Conveyance Company Limited at ~~and~~ Codial bail, Mangalore and consist of a gas-tight tank of a capacity of 500 gallons sunk underground.

Issued
21.5.30
SLP
21.5.30

M/S

Conditions of license.

1. Except when absolutely necessary for the purposes of condition 8 or for testing the accuracy of a pump's discharge by means of a standard capacity measure or when the tank and pump are erected completely inside a Dangerous Petroleum, Acetone, Wood Naptha and Methyl Alcohol Installation, petroleum, acetone, wood naptha and methyl alcohol shall on no account be filled from the tank or pump or from a barrel of oil supplied by Petroleum, Acetone, Wood Naptha and Methyl Alcohol Companies to be filled into the tank, into any receptacle other than that clamped or fitted to a Motor Vehicle.

2. The petroleum, acetone, wood naptha and methyl alcohol shall be stored in one gas-tight metal tank of a capacity of gallons sunk completely underground in the position shown on plan submitted, and placed in a pit lined with concrete or brick in cement, the tank being packed round with sand, earth or clay, so that no air space is left below ground level and the tank is not visible.

3. A pump or pumps shall be placed in the position shown on plan submitted, the pipe connection between the tank and the pump or pumps shall be placed underground and all joints, valves and cocks shall be gas-tight.

4. For the purpose of charging the tanks of locomotives the petroleum, acetone, wood naptha and methyl alcohol shall be—

(*a*) pumped through strong metal piping by means of approved pumps into above-ground measuring tanks of a capacity not exceeding 30 gallons, fixed in approved positions, and run thence through sound hose, fitted with secure self-closing cock and nozzle, into the tanks of locomotives, or

(*b*) pumped through strong metal piping by means of approved pumps into an above-ground service tank of approved capacity, fixed in an approved position, and run thence through strong metal piping into measuring tanks of a capacity not exceeding 30 gallons fixed in approved positions and thence through sound hose, fitted with secure self-closing cock and nozzle, into the tanks of locomotives, or

(*c*) pumped by means of approved measuring pumps, fixed in approved positions, through sound hose fitted with secure tap and nozzle, into the tanks of locomotives.

5. All tanks, pumps, pipes and fittings shall be strongly constructed of the best materials.

6. The petroleum, ~~acetone, wood naptha and methyl alcohol~~ shall enter the tank "under seal" and all tanks shall be fitted with a vent pipe leading into the open air, the open end being covered with brass gauze, 32 mesh, and fitted with a hood or the open end shall be fitted with an inlet valve and an exhaust valve.

7. If the licensing officer call upon the holder of a license by a notice in writing, to execute any repairs to the storage premises, which may, in the opinion of such officer, be necessary for the safety of the said premises, the holder of the license shall execute the repairs within such period, not being less than one month from the date of receipt of the notice as may be fixed by the notice.

8. The tank, before being repaired, shall be cleared of all dangerous petroleum, acetone, wood naptha and methyl alcohol and of all dangerous vapours arising from the same. When a tank in position is open for cleaning or repairs no lamps of any description either ordinary, electric, electric torches or electric cables or electric fans shall be brought near the manhole of the tank (the inside of the tank may be lighted by the use of mirrors).

9. The license holder is prohibited from delivering any quantity of dangerous petroleum, acetone, wood naptha and methyl alcohol exceeding three gallons to any one who has not a license under section 5 or section 6 of the Act.

10. All due precautions shall be taken for the prevention of unauthorised persons having access to any petroleum, acetone, wood naptha and methyl alcohol kept and to the vessels containing or having actually contained the same.

11. Every person managing or employed on or in connection with the storage premises shall abstain from any act whatever which tends to cause fire or explosion and which is not reasonably necessary, and shall prevent any other person from doing such act. No fire or naked light shall be allowed to burn and no smoking or the lighting of any match shall be permitted within ten feet of a kerbside pump.

12. The storage premises shall be liable to inspection by an officer not being of lower rank than a Sub-Inspector of Police authorised by the Local Government in this behalf.

13. This license shall be held to cover the use of a portable kerbside pump outfit for a period of not more than one month in the place of the licensed permanent outfit in the event of the latter being out of order, provided notice in writing is given to the District Authority before the portable pump is taken into use.

GIPD—380-Std. S. (Agency)—25-1-30—500.